

DC-2022/Estate/ Fire system/ 1147

13 December, 2022

### TENDER NOTICE

DCCI Authority has decided to upgrade/ develop the existing fire control system at DCCI building.

#### Details of Existing Fire Control system:

1. FDS (Fire detection system) – There is an addressable fire control panel (**Simplex brand**) containing a circuit/ loop of fire alarm, MPS (manual pull station), smoke detector & heat detector (4<sup>th</sup>, 5<sup>th</sup> and 6<sup>th</sup> floor).
2. FPS (Fire protection system) – There is a Water Hydrant system containing water Hose Pipe at every floor (from ground floor to 11th floor) and a water reservoir tank at 11th floor.

#### Work Schedule:

1. You have to supply & install the below following items:
  - a. Manual call point – 10 Nos
  - b. Smoke detector – 12 Nos
  - c. Control/Output Module – 04 Nos
  - d. Isolator Module – 04 Nos
  - e. Addressable Sounder – 10 Nos
  - f. Automatic Fire Extinguisher (Fire ball) – 15 Nos
  - g. Fire rated cable & PVC conduit – as need
2. Testing & Commissioning
3. As-built design drawing of whole fire system with supplementary document.

(All the supplied items must be original Simplex brand, UL, ULC listed & FM approved)

Regarding the above task, you are invited to submit your financial offer in the tender box by **24 December, 2022** at 3:00 pm, which is kept at DCCI Estate section (4<sup>th</sup> floor).

#### Terms & Conditions:

1. You have to submit financial offers in time after physical assessment if any. No offers will be taken after the scheduled date and time.
- 2. You must be expert & well experienced in Fire Control System.**
3. VAT & Tax must be included in your financial offer.
4. DCCI Authority preserves the right to accept or, cancel any tender/offer.



Afsarul Arifeen

Secretary General, DCCI